

PID Configuration

PID - Rung #2:0 - N10:0

Controller Gain, Kc: 1.2	Setpoint: 120
Reset Term, Ti: 2.7	Maximum Setpoint Limit: 200
Rate Term, Td: 0.00	Minimum Setpoint Limit: 0
Loop Update Time: 0.10	Control Variable Percent (CV%): 60
Control Mode: E = SP - PV	Output Max CV(%): 100
PID Control: Manual	Output Min CV(%): 0
Time Mode: Timed	Derivative Action(DA): No
Output Limiting: Yes	Deadband: 0
Reset and Gain: No	

