

OB1 - <offline>

"Cycle Execution"

Name:

Author:

Time stamp Code:

Lengths (block/logic/data):

Family:

Version: 0.1

Block version: 2

12/27/2015 06:30:47 AM

02/15/1996 04:51:12 PM

00224 00098 00026

Name	Data Type	Address	Comment
TEMP		0.0	
OB1_EV_CLASS	Byte	0.0	Bits 0-3 = 1 (Coming event), Bits 4-7 = 1 (Event class 1)
OB1_SCAN_1	Byte	1.0	1 (Cold restart scan 1 of OB 1), 3 (Scan 2-n of OB 1)
OB1_PRIORITY	Byte	2.0	Priority of OB Execution
OB1_OB_NUMBR	Byte	3.0	1 (Organization block 1, OB1)
OB1_RESERVED_1	Byte	4.0	Reserved for system
OB1_RESERVED_2	Byte	5.0	Reserved for system
OB1_PREV_CYCLE	Int	6.0	Cycle time of previous OB1 scan (milliseconds)
OB1_MIN_CYCLE	Int	8.0	Minimum cycle time of OB1 (milliseconds)
OB1_MAX_CYCLE	Int	10.0	Maximum cycle time of OB1 (milliseconds)
OB1_DATE_TIME	Date_And_Time	12.0	Date and time OB1 started

Block: OB1 "Main Program Sweep (Cycle)"


Copyright (c) 2011, 2015 Dogwood Valley Press, LLC

SP 5-5 Switch press counter

Additional internal memory:
Symbol Address
Ctrl DB2 (SFB0) Counts items

Network: 1 Counts 20 presses of PB151

Counter resets itself at 20 so that more pb presses can be counted while PL612 is on.



Network: 2	Pilot light control
When 20 have been counted, latch PL612. When PB613 is activated, unlatch PL612.	

