


PID Configuration


PID - Rung #2:22 - PD15:0


Controller Gain, Kc: 0.4	Setpoint: 40
Reset Term, Ti: 0.10	Setpoint MAX(Smax): 100
Rate Term, Td: 0.00	Setpoint MIN(Smin): 0
Loop Update Time: 0.25	Process Variable PV: 0
Control Mode: E = SP - PV	Control Output CV (%): 0
PID Control: Auto	Output Max CV(%): 100
Time Mode: STI	Output Min CV(%): 0
Limit Output CV: Yes	Scaled Error: 0
Deadband: 0	Feed Forward Bias: 0

PID - Rung #2:25 - PD15:1

Controller Gain, Kc: 0.4	Setpoint: 40
Reset Term, Ti: 0.10	Setpoint MAX(Smax): 100
Rate Term, Td: 0.00	Setpoint MIN(Smin): 0
Loop Update Time: 0.25	Process Variable PV: 0
Control Mode: E = SP - PV	Control Output CV (%): 0
PID Control: Auto	Output Max CV(%): 100
Time Mode: STI	Output Min CV(%): 0
Limit Output CV: Yes	Scaled Error: 0
Deadband: 0	Feed Forward Bias: 0







Convert level measurement into units of feet. SCP can only work with integer destination. Use SCP to convert to hundredths of feet and then divide by 100 to get level in feet.

0010

SCP	
Scale w/Parameters	
Input	I:1.0
	0<
Input Min.	6241
	6241<
Input Max.	31206
	31206<
Scaled Min.	0
	0<
Scaled Max.	1500
	1500<
Output	N14:5
	0<

Reactor vessel level
in feet

LT104_VAL

MUL	
Multiply	
Source A	N14:5
	0<
Source B	0.01
	0.01<
Dest	F13:5
	0.0<

Reset of accumulators in prestart step

Prestart checks

STEP_1

B20/1

FIC101 accumulation

FIC101_ACC

MOV	
Move	
Source	0.0
	0.0<
Dest	F12:6
	0.0<

FIC102 accumulation

FIC102_ACC

MOV	
Move	
Source	0.0
	0.0<
Dest	F12:9
	0.0<

0011

FIC101 setpoint moves. Set to -2.0 except when filling ingredient A.

Add A

STEP_2

B20/2


FIC101 setpoint


FIC101_SP


MOV	
Move	
Source	F12:0
	0.0<
Dest	F12:7
	0.0<

0012









RSLogix 500 Cross Reference Report - Sorted by Address

O:0/0	- {A105_SLOW} Agitator slow control OTE - File #2 - 20
O:0/1	- {A105_FAST} Agitator fast control OTE - File #2 - 21
O:0/2	- {XV101_OPEN} XV101 open control OTE - File #2 - 16
O:0/3	- {XV102_OPEN} XV102 open control OTE - File #2 - 17
O:0/4	- {XV103_OPEN} XV102 open control OTE - File #2 - 18
O:0/5	- {P103_RUN} Outlet pump motor control OTE - File #2 - 19
O:2.0	- {FY101} Ingred A flow valve control PID - File #2 - 22
O:2.1	- {FY102} Ingred B flow valve control PID - File #2 - 25
I:0/0	- {START_PB} Start pushbutton XIC - File #2 - 0
I:0/1	- {STOP_PB} Stop pushbutton XIC - File #2 - 0
I:1.0	- SCP - File #2 - 10
I:1.1	- PID - File #2 - 22
I:1.2	- PID - File #2 - 25
T4:0	- {AGIT_TMR} Agitation timer TON - File #2 - 7
T4:0/DN	- XIC - File #2 - 7
T4:0.ACC	- MUL - File #2 - 7
T4:2	- {ACCUM_TMR} Accumulator timer TON - File #2 - 28
T4:2/DN	- XIC - File #2 - 29 XIO - File #2 - 28
F12:0	- {INGA_DES_FLW} Ingredient A desired flow rate MOV - File #2 - 12
F12:1	- {INGA_DES_AMT} Ingredient A desired amount GEQ - File #2 - 3
F12:2	- {INGB_DES_FLW} Ingredient B desired flow rate MOV - File #2 - 14
F12:3	- {INGB_DES_AMT} Ingredient B desired amount GEQ - File #2 - 5
F12:4	- {AGIT_TIME} Agitation time in minutes MUL - File #2 - 7
F12:5	- {FIC101_PV} FIC101 process variable MOV - File #2 - 24 DIV - File #2 - 29 EQU - File #2 - 2 LES - File #2 - 4
F12:6	- {FIC101_ACC} FIC101 accumulation MOV - File #2 - 11 ADD - File #2 - 29 EQU - File #2 - 2 GEQ - File #2 - 3
F12:7	- {FIC101_SP} FIC101 setpoint MOV - File #2 - 12, 13, 24
F12:8	- {FIC102_PV} FIC102 process variable MOV - File #2 - 27 ADD - File #2 - 29 DIV - File #2 - 29 EQU - File #2 - 2 LES - File #2 - 6
F12:9	- {FIC102_ACC} FIC102 accumulation MOV - File #2 - 11 EQU - File #2 - 2 GEQ - File #2 - 5
F12:10	- {FIC102_SP} FIC102 setpoint MOV - File #2 - 14, 15, 27
F12:11	- {TEMP_ACC} Used in calculation of accumulations

RSLogix 500 Cross Reference Report - Sorted by Address

```

F13:5      ADD - File #2 - 29
           DIV - File #2 - 29
           - {LT104_VAL} Reactor vessel level in feet
           MUL - File #2 - 10
           LES - File #2 - 2, 8
N14:5      - MUL - File #2 - 10
           SCP - File #2 - 10
PD15:0     - {FIC101} Ingredient A flow control
           PID - File #2 - 22
PD15:0/AM  - {FIC101_MD}
           OTE - File #2 - 23
PD15:0.SPS - {FIC101_INTSP}
           MOV - File #2 - 24
PD15:0.SPV - {FIC101_INTPV}
           MOV - File #2 - 24, 27
PD15:1     - {FIC102} Ingredient B flow control
           PID - File #2 - 25
PD15:1/AM  - {FIC102_MD}
           OTE - File #2 - 26
PD15:1.SPS - {FIC102_INTSP}
           MOV - File #2 - 27
B20/0      - {RUN} Station running
           OTE - File #2 - 0
           XIC - File #2 - 0, 1, 16, 17, 18, 19
           XIO - File #2 - 9, 23, 26
B20/1      - {STEP_1} Prestart checks
           OTL - File #2 - 1
           OTU - File #2 - 2
           XIC - File #2 - 2, 11
           XIO - File #2 - 1
B20/2      - {STEP_2} Add A
           OTL - File #2 - 2
           OTU - File #2 - 3
           XIC - File #2 - 3, 12, 16
           XIO - File #2 - 1, 13
B20/3      - {STEP_3} Wait for A shutoff
           OTL - File #2 - 3
           OTU - File #2 - 4
           XIC - File #2 - 4
           XIO - File #2 - 1
B20/4      - {STEP_4} Add B
           OTL - File #2 - 4
           OTU - File #2 - 5
           XIC - File #2 - 5, 14, 17, 20
           XIO - File #2 - 1, 15
B20/5      - {STEP_5} Wait for B shutoff
           OTL - File #2 - 5
           OTU - File #2 - 6
           XIC - File #2 - 6, 20
           XIO - File #2 - 1
B20/6      - {STEP_6} Agitate fast
           OTL - File #2 - 6
           OTU - File #2 - 7
           XIC - File #2 - 7, 21
           XIO - File #2 - 1
B20/7      - {STEP_7} Dump tank
           OTL - File #2 - 7
           OTU - File #2 - 8
           XIC - File #2 - 8, 18, 19, 20
           XIO - File #2 - 1
B20/8      - {STEP_8} Unlatch run
           OTL - File #2 - 8
           OTU - File #2 - 9
           XIC - File #2 - 9
           XIO - File #2 - 0, 1
B20/40     - {INT_RESET} Reset in progress

```